

48 HAMPSHIRE STREET HOUSING

48 Hampshire Street, Auburn, Maine
Platz Project #201712
MaineHousing Project #MSHA-RLP-1676

ADDENDUM #1

December 10, 2018

CIVIL

1. Sewer line invert elevation at the building exit shall be elevation 184.92'. Invert at sewer connection to the sanitary manhole shall be as required while maintaining a minimum 2% slope from the building exit elevation. Invert at interior slab penetration shall be as required while maintaining a minimum 2% slope within the building from the building sewer exit elevation.
2. See revised existing conditions survey plan dated 11/29/2018.

ELECTRICAL

3. On Sheet E000, Fire Alarm Symbols - Devices marked as SB, remove references to sounder bases. The non-system local units are to be 120V single station only.
4. On Sheet E301, in ADA Units 102 and 202 - System Connected Fire Alarm Visual Strobe Only should be included in living room and bedrooms. In addition to system connected strobes these units should have strobe units operated by the single station detectors in living room, bathroom and bedrooms.