

300 UNICORN PARK DRIVE, 5TH FLOOR
WOBURN, MA 01801
(P) 781.481.0210 (F) 781.481.0203 (W) www.f-t.com

PROJECT: Fresenius Water Sys Upgr - Bath
F&T PROJECT NO.: 190067.01
RECEIVED FROM: ftconadmin,
SENT TO: Henry Glennon,
RFI #: 011
DATE RECEIVED: 5/23/2019
REVIEWED BY: ftconadmin
REVIEW DATE: 5/28/2019
SUBJECT: 19.10 FKC Bath RFI #11

RFI RESPONSE:

The existing floor drain at this location is to be removed and replaced with new as indicated on drawing P301U.

This response is not a directive authorizing an increase in construction cost or time. This response does not constitute an approval, direction or procedure related to construction means, methods, techniques, sequences or procedures of the contractor.

This response does not constitute an approval, direction or procedure related to construction site safety precautions, procedures, or methodology of the contractor.

